



Government of West Bengal
Department of Fire and Emergency Services
Newtown Fire Station (2nd & 3rd Floor)
Action area-I, Plot No.- CF-7, Street Number-175
Newtown, Kolkata-7000156

ofc

No. : 1985/FES-15011/25/2018

Date: 07/02/2025

From : The Senior Special Secretary
to the Government of West Bengal

To : 1) The Chief Secretary to the Government of West Bengal,
2) The Additional Chief Secretary/Principal Secretary/
Secretary,.....All.....Department,
3) The District Magistrate,..... (All).....District,
4) The Commissioner of Police, Kolkata,
5) The Director,WBF&ES,
6) The ALO of WBF&ES,

Sub : Increasing the limit of Storage of Superior Kerosene Oil(in short SK Oil) up to 5000 litres instead of 2000 litres in order to issue fire license by the District Magistrate.

Sir/Madam,

I am directed to inform you that the limit of Storage of Superior Kerosene Oil(in short- SK Oil) increasing up to 5000 litres instead of 2000 litres towards issuance of Fire License by the District Magistrates within their respective jurisdiction under the authority delegated to them by the Notification No. 549-FES/O/2E-12/2004, dated: 16.06.2006 read with the Order No. 1894-FES/O/2E-12/2004(pt-1), dated: 28.12.2012 of this Department.

Yours faithfully

[Signature]
Sr. Special Secretary
to the Government of West Bengal

No. : 1985/FES-15011/25/2018

Date: 07/02/2025

Copy forwarded for information to :

1. The P.S to Hon'ble MOS, Department of Fire & Emergency Services,
2. The Sr. P.S to Principal Secretary, Department of Fire & Emergency Services,
3. Guard File.

[Signature]
Sr. Special Secretary
to the Government of West Bengal